

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 18/4/2023

It is certified that an inspection team headed by Shorad Duvadi  
 (Name of Officers with designation) from Nagar Palika, Shahdol  
 (Name of Department/ Office) inspected the Maharishi Vidya Mandir, Kalyanpur, Shahdol  
 (Name & Address of the school) on 18/4/2023 (date of inspection) and found that  
 the Maharishi Vidya Mandir, Shahdol (Name of school) has safe drinking water facilities  
 for the students and members of staff of the institution and is maintaining the hygienic sanitation  
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
 The above is valid for a period of 1 year

Signature with Seal: .....

Name

Designation

Name &amp; Address of the Office / Department : .....

To

The Principal  
Maharishi Vidya Mandir  
Shahdol (M.P) 484001  
 (Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Self attested  
 Dr. Bhavna Tiwari

130

Principal  
 Dr. Bhavna Tiwari  
 Maharishi Vidya Mandir  
 Shahdol (M.P.)  
 CBSE AFFILIATION No. 1030422  
 School Code - 50392

# DISTRICT WATER TESTING LABORATORY

Public Health Engineering Deptt. Shahdol

DISTRICT - Shahdol

BLOCK - Sehagpur VILLAGE

<u>Kalyanpur</u>

Code No .....

Code No .....

Particular of Sample

SA. No. & Details of Source & Location

(1) Date of Collection 11.5.2023 (i)

(2) Date of Analysis 11.5.2023 (ii) 563-

(iii) Maharishi Vidhya Mandir  
(iv) Shahdol (M.P)

Table - 2.2 BIS Standard : Is - 10500-1991

Result

S. No.	Characteristics	Unit	Require Desirable Limit	Permissible limit in the absence of alternative source	Sample No.
<b>PHYSICAL TEST</b>					<b>563</b>
1.	Turbidity	N.T.U.	5	10	0.40
2.	Colour	Hazen Units	5.0	25	0
3.	Taste	-	Agreeable	-	Agreeable
4.	Odour	-	Unobjectionable	-	Unobjectionable
<b>CHEMICAL TEST</b>					
4.	PH	PH Scale	7.0 To 8.5	No relaxation	7.2
5.	Conductivity	Micro Mhos/cm	-	-	364
6.	Total Alkalinity	mg/l	200	600	20
7.	Chlorides (As Cl)	mg/l	250	1000	25
8.	Nitrates (As NO <sub>3</sub> )	mg/l	45	45	10
9.	Total Hardness (As CaCo <sub>3</sub> )	mg/l	300	600	120
10.	Total Dissolved Solids	mg/l	500	2000	196
11.	Iron (As Fee)	mg/l	0.3	1.00	0.3
12.	Fluorides (As F)	mg/l	1.00	1.5	0
13.	Sulphates (As SO <sub>4</sub> )	mg/l	200	400	15
14.	Residual Chlorine	mg/l	0.2	-	0
<b>BACTERIOLOGICAL TEST</b>					
15.	Coliform Organisms at 37 <sup>o</sup> c	M.P.N./100ml.	-	-	NIL

TESTED BY - Vinita Bajpai  
REMARKS - .....

*Self attested*  
Bhavana Tiwari  
Principal  
Dr. Bhavana Tiwari  
Maharishi Vidya Mandir  
Shahdol (M.P.)  
CBSE AFFILIATION No. 1030422  
School Code - 50392

[Signature]  
Chemist  
Name & Signature  
Of Lab In Charge

का. सहायक जे. बी. ब्लॉक स्नातकोत्तरी उपखण्ड-शहडोल (म.प्र.)

क्र. 313 / प्र. शा. सं. सं.

दिनांक 11/5/23

प्रति,  
प्राचार्य  
महाश्री विद्या मंदिर  
शहडोल (म.प्र.)

विषय - पानी की जांच कराने बाबत

संदर्भ - आपका पत्र क्र. 8158 दिनांक 11.5.2023.

उपरोक्त विषय में लेख है कि संदर्भित पत्र

के साथ एक नया जल नमूना परीक्षण हेतु प्राप्त हुआ  
नमूने का भौतिक, रासायनिक तथा जीवाणु परीक्षण  
कर रिपोर्ट आपकी ओर प्रेषित है।

संलग्न - उपरोक्तानुसार  
सै. नं. 563.

A. B. Tiwari  
A. B. Tiwari  
जो. डाय. डॉ. शहडोल (म.प्र.)  
A. B. Tiwari

Self attested.

*Tiwari*

Principal

Dr. Bhavana Tiwari

Maharishi Vidya Mandir

Shahdol (M.P.)

CBSE AFFILIATION No. 1030422

School Code - 50392